## §75.1913

- (2) Records are to be kept manually in a secure manner not susceptible to alteration or recorded electronically in a secured computer system that is not susceptible to alteration.
- (3) Records shall be maintained at a surface location at the mine for one year and made available for inspection by an authorized representative of the Secretary and miners' representatives.
- (j) All miners normally assigned to the active workings of the mine shall be instructed about the hazards inherent to the operation of the fire suppression systems and, where appropriate, the safeguards available for each system

[61 FR 55527, Oct. 25, 1996; 70 FR 36347, June 23, 2005]

## §75.1913 Starting aids.

- (a) Volatile fuel starting aids shall be used in accordance with recommendations provided by the starting aid manufacturer, the engine manufacturer, and the machine manufacturer.
- (b) Containers of volatile fuel starting aids shall be conspicuously marked to indicate the contents. When not in use, containers of volatile fuel starting aids shall be stored in metal enclosures that are used only for storage of starting aids. Such metal enclosures must be conspicuously marked, secured, and protected from damage.
- (c) Volatile fuel starting aids shall not be:
- (1) Taken into or used in areas where permissible equipment is required;
- (2) Used in the presence of open flames or burning flame safety lamps, or when welding or cutting is taking place; or
- (3) Used in any area where 1.0 percent or greater concentration of methane is present.
- (d) Compressed oxygen or compressed flammable gases shall not be connected to diesel air-start systems.

## § 75.1914 Maintenance of diesel-powered equipment.

- (a) Diesel-powered equipment shall be maintained in approved and safe condition or removed from service.
- (b) Maintenance and repairs of approved features and those features required by §§ 75.1909 and 75.1910 on diesel-

- powered equipment shall be made only by a person qualified under §75.1915.
- (c) The water scrubber system on diesel-powered equipment shall be drained and flushed, by a person who is trained to perform this task, at least once on each shift in which the equipment is operated.
- (d) The intake air filter on dieselpowered equipment shall be replaced or serviced, by a person who is trained to perform this task, when the intake air pressure drop device so indicates or when the engine manufacturer's maximum allowable air pressure drop level is exceeded.
- (e) Mobile diesel-powered equipment that is to be used during a shift shall be visually examined by the equipment operator before being placed in operation. Equipment defects affecting safety shall be reported promptly to the mine operator.
- (f) All diesel-powered equipment shall be examined and tested weekly by a person qualified under §75.1915.
- (1) Examinations and tests shall be conducted in accordance with approved checklists and manufacturers' maintenance manuals.
- (2) Persons performing weekly examinations and tests of diesel-powered equipment under this paragraph shall make a record when the equipment is not in approved or safe condition. The record shall include the equipment that is not in approved or safe condition, the defect found, and the corrective action taken.
- (g) Undiluted exhaust emissions of diesel engines in diesel-powered equipment approved under part 36 and heavy-duty nonpermissible diesel-powered equipment as defined in §75.1908(a) in use in underground coal mines shall be tested and evaluated weekly by a person who is trained to perform this task. The mine operator shall develop and implement written standard operating procedures for such testing and evaluation that specify the following:
- (1) The method of achieving a repeatable loaded engine operating condition for each type of equipment;
- (2) Sampling and analytical methods (including calibration of instrumentation) that are capable of accurately detecting carbon monoxide in the expected concentrations;